

**Northern Power Distribution Company of A.P Limited
Warangal**

FORMAT - 2

Daily Report on power supply position as on 18.01.2012

| Sl. No. | District | Energy (MU) | | | Demand (MW) | | |
|--------------------|------------|---------------|---------------|---------------|----------------|----------------|---------------------------|
| | | Required | Met | Deficit (-) | Un-Restricted | Peak Met | Deficit (-) / Surplus (+) |
| 1 | Warangal | 7.850 | 7.850 | 0.000 | 345.25 | 345.25 | 0.00 |
| 2 | Karimnagar | 10.535 | 9.155 | -1.380 | 478.80 | 478.80 | 0.00 |
| 3 | Khammam | 4.342 | 4.342 | 0.000 | 250.50 | 250.50 | 0.00 |
| 4 | Nizamabad | 7.839 | 7.839 | 0.000 | 330.00 | 330.00 | 0.00 |
| 5 | Adilabad | 4.908 | 4.908 | 0.000 | 211.80 | 211.80 | 0.00 |
| NPDCL Total | | 35.474 | 34.094 | -1.380 | 1653.00 | 1653.00 | 0.00 |

**Northern Power Distribution Company of A.P Limited
Warangal**

FORMAT - 3

Daily Report on power supply position as on 18.01.2012

| Sl. No. | District | No. of 11 KV feeders existing | | No. of 11 KV feeders for which scheduled hours of supply maintained for lighting | | Agricultural Supply (No. of feeders) | | | | | | | |
|---------|--------------------|-------------------------------|-------------|--|-------------|--------------------------------------|------------------------|---------------------|------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------|
| | | Urban | Rural | Urban | Rural | Existing No. of feeders | 7Hours in Single Spell | 7 Hours in 2 Spells | 7Hours in more than 2 spells | 7 Hours in more than 3 spells | 7 Hours in more than 4 spells | 7 Hours in more than 5 spells | Less than 7 Hours |
| 1 | Warangal | 204 | 561 | 204 | 561 | 561 | 187 | 374 | 0 | 0 | 0 | 0 | 0 |
| 2 | Karimnagar | 348 | 693 | 348 | 693 | 693 | 65 | 628 | 0 | 0 | 0 | 0 | 0 |
| 3 | Khammam | 108 | 305 | 108 | 305 | 305 | 116 | 189 | 0 | 0 | 0 | 0 | 0 |
| 4 | Nizamabad | 298 | 665 | 298 | 665 | 665 | 566 | 99 | 0 | 0 | 0 | 0 | 0 |
| 5 | Adilabad | 80 | 287 | 80 | 287 | 287 | 133 | 154 | 0 | 0 | 0 | 0 | 0 |
| | NPDCL Total | 1038 | 2511 | 1038 | 2511 | 2511 | 1067 | 1444 | 0 | 0 | 0 | 0 | 0 |

**Northern Power Distribution Company of A.P Limited
Warangal**

FORMAT - 4

Daily Report on power supply position as on 18.01.2012

| Sl. No. | District | 11 KV/33 KV feeders | | | | | | Weather Report |
|---------|---------------------|---------------------|--|----------------------------------|-------------------------|---|---------------------------------|----------------|
| | | Total Feeders | No. of spill over feeder breakdowns pending as on previous day | No. of breakdowns during the day | Total No. of breakdowns | No. of breakdowns attended during the day | Balance feeders under breakdown | |
| 1 | Warangal | 837 | 0 | 1 | 1 | 1 | 0 | clear |
| 2 | Karimnagar | 1072 | 0 | 0 | 0 | 0 | 0 | clear |
| 3 | Khammam | 422 | 0 | 0 | 0 | 0 | 0 | clear |
| 4 | Nizamabad | 1042 | 0 | 0 | 0 | 0 | 0 | Clear |
| 5 | Adilabad | 459 | 0 | 0 | 0 | 0 | 0 | Clear |
| | NPDCCL Total | 3832 | 0 | 1 | 1 | 1 | 0 | |

**Northern Power Distribution Company of A.P Limited
Warangal**

Format - 5

Daily Report on power supply position as on 18.01.2012

| Sl. No. | District | No. of DTRs yet to be replaced | No. of DTRs failed during the day | Total No. of DTRs failed | No. of DTRs replaced during the day | Violations | | No. of DTRs yet to be replaced | Healthy Stock Available |
|--------------------|------------|--------------------------------|-----------------------------------|--------------------------|-------------------------------------|------------|----------|--------------------------------|-------------------------|
| | | | | | | Urban | Rural | | |
| 1 | Warangal | 0 | 21 | 21 | 21 | 0 | 0 | 0 | 42 |
| 2 | Karimnagar | 0 | 21 | 21 | 21 | 0 | 0 | 0 | 496 |
| 3 | Khammam | 0 | 13 | 13 | 13 | 0 | 0 | 0 | 74 |
| 4 | Nizamabad | 0 | 12 | 12 | 12 | 0 | 0 | 0 | 52 |
| 5 | Adilabad | 0 | 6 | 6 | 6 | 0 | 0 | 0 | 84 |
| NPDCL Total | | 0 | 73 | 73 | 73 | 0 | 0 | 0 | 748 |

| Annexure-Break Downs | | | | | | | | | Weather Report |
|---|-----------------|---------------|-----------------------|-------------|--------------|-------|------------------|--|----------------|
| Date:18-01-2012(33/11 KV - B/D) 11KV Break downs | | | | | | | | | |
| Circle | No.of 11 KV B/D | DIVISION | 33/11 KV Sub-station | 11 KVFeeder | Interruption | | | Remarks | |
| | | | | | From | To | Duration (hours) | | |
| Warangal | Nil | | | | | | | | |
| Karimnagar | Nil | | | | | | | | |
| Khammam | Nil | | | | | | | | |
| Nizamabad | Nil | | | | | | | | |
| Adilabad | Nil | | | | | | | | |
| 33KV Break downs | | | | | | | | | |
| Circle | No.of 33 KV B/D | DIVISION | 132/33 KV Sub-station | 33 KVFeeder | Interruption | | | Remarks | |
| | | | | | From | To | Duration (hours) | | |
| Warangal | 1 | C&O, Warangal | Waddepally | Chintahattu | 12.05 | 17.45 | 5.40 | Jumper cut near by 132/33 KV ss; Rectified | |
| Karimnagar | Nil | | | | | | | | |
| Khammam | Nil | | | | | | | | |
| Nizamabad | Nil | | | | | | | | |
| Adilabad | Nil | | | | | | | | |

Clear

DETAILS OF AGL FEEDERS SUPPLY GIVEN MORE THAN 2 SPELLS
(In continuation of Format - 3)

DATE 18.01.2012

| Sl.no | Name of the Circle | Division Name | Sub-Station Name | Feeder Name | No.of Spells | Total Duration |
|-------|--------------------|---------------|------------------|-------------|--------------|----------------|
| 1 | Warangal | | 0 | | | |
| 2 | Karimnagar | | 0 | | | |
| 3 | Khammam | | 0 | | | |
| 4 | Nizamabad | | 0 | | | |
| 5 | Adilabad | | 0 | | | |
| | Total | | 0 | | | |

| ANNEXURE-33 KV FEEDER LOAD RELIEF | | | | | | | | |
|--|-------------------|-----------------------------------|--------------------------|-------------------------|------------------------|----------------------------|----------------|---------------------------|
| DT 18-01-2012 | | | | | | | | |
| Sl.No | Circle | No.of 33KVfeeders existing | No.of L/R feeders | Duration (hours) | TOTAL L.R (M.U) | AGL L.R COMPENSATED | NET L.R | Remarks |
| 1 | Warangal | 66 | 6 | 6.00 | 0.030 | 0.030 | 0.000 | AGL LR Compensated |
| 2 | Karimnagar | 92 | 4.2 | 1.05 | 1.4010 | 0.0210 | 1.3800 | |
| 3 | Khammam | 45 | 9 | 10.43 | 0.052 | 0.052 | 0.000 | |
| 4 | Nizamabad | 94 | 6 | 6.00 | 0.030 | 0.030 | 0.000 | |
| 5 | Adilabad | 37 | 16 | 34.30 | 0.102 | 0.102 | 0.000 | |
| | Total | 334 | 41 | 52.18 | 1.615 | 0.235 | 1.380 | |

| LOAD RELIEF (MU) BREAK-UP ON 18/01/2012 | | | | | |
|---|-------|-------|-------|--------------|-------|
| DISCOM | CPDCL | SPDCL | EPDCL | NPDCL | TOTAL |
| GHMC (for CPDCL only) | | | | | |
| DHQs | | | | 0.000 | |
| Corporations | | | | 0.000 | |
| Municipalities | | | | 0.000 | |
| Mandals | | | | 0.000 | |
| Villages | | | | 0.000 | |
| TOTAL | | | | 0.000 | |

NORTHERN POWER DISTRIBUTION COMPANY OF A.P.LTD

Daily Report on power supply position as on 18.01.2012

| Sl. No | Work | | Name of the Circle | | | | | APNPDCL |
|--------|----------------------------|--|--------------------|------------|---------|-----------|----------|---------|
| | | | Warangal | Karimnagar | Khammam | Nizamabad | Adilabad | |
| 1 | Release of AGL Services | Target for 2011-2012 | 6996 | 16459 | 7118 | 12590 | 6184 | 49347 |
| | | AGL Services Released during the day | 0 | 0 | 0 | 0 | 0 | 0 |
| | | AGL services Released upto date | 6551 | 3865 | 3437 | 6955 | 2760 | 23568 |
| 2 | Electrification of Schools | No.of services amount received | 0 | 0 | 0 | 0 | 0 | 0 |
| | | No.of services released during day | 0 | 0 | 0 | 0 | 0 | 0 |
| | | Total No.of services released upto date | 1684 | 564 | 1102 | 814 | 1249 | 5413 |
| 3 | Revenue collection | Revenue collection during the day (in Lakhs) | 54.18 | 72.12 | 56.18 | 66.24 | 58.56 | 307.28 |

| ANNEXURE-33 KV FEEDER LOAD RELIEF | | | | | | | | | | |
|-----------------------------------|------------|-----------------|---------------------|---------|-----------------|----------------------|---------|-----------------|----------------------|---------|
| Sl.No | Circle | Dt:02.01.2012 | | | Dt:03.01.2012 | | | Dt:05.01.2012 | | |
| | | TOTAL L.R (M.U) | AGL L.R COMPENSATED | NET L.R | TOTAL L.R (M.U) | AGL L.R COMPE NSATED | NET L.R | TOTAL L.R (M.U) | AGL L.R COMPE NSATED | NET L.R |
| 1 | Warangal | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | | | |
| 2 | Karimnagar | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.270 | 0.000 | 0.270 |
| 3 | Khammam | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 4 | Nizamabad | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 5 | Adilabad | 0.300 | 0.000 | 0.300 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| | Total | 0.300 | 0.000 | 0.300 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| | | | | | | | | 0.270 | 0.000 | 0.270 |

ANNEXURE-33 KV FEEDER LOAD RELIEF

| Sl.No | Circle | Dt:06.01.2012 | | | Dt:07.01.2012 | | | Dt:08.01.2012 | | | Dt:09.01.2012 | | |
|-------|------------|-----------------|---------------------|---------|-----------------|----------------------|---------|-----------------|----------------------|---------|-----------------|---------------------|---------|
| | | TOTAL L.R (M.U) | AGL L.R COMPENSATED | NET L.R | TOTAL L.R (M.U) | AGL L.R COMPE NSATED | NET L.R | TOTAL L.R (M.U) | AGL L.R COMPE NSATED | NET L.R | TOTAL L.R (M.U) | AGL L.R COMPENSATED | NET L.R |
| 1 | Warangal | 0.092 | 0.092 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 2 | Karimnagar | 0.000 | 0.000 | 0.000 | 0.010 | 0.010 | 0.000 | 0.000 | 0.000 | 0.000 | 0.032 | 0.032 | 0.000 |
| 3 | Khammam | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 4 | Nizamabad | 0.600 | 0.000 | 0.600 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.031 | 0.031 | 0.000 |
| 5 | Adilabad | 0.000 | 0.000 | 0.000 | 0.600 | 0.000 | 0.600 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| | Total | 0.692 | 0.092 | 0.600 | 0.610 | 0.010 | 0.600 | 0.000 | 0.000 | 0.000 | 0.063 | 0.063 | 0.000 |

